


EXCAVATION DIMENSIONS:

126" DIAMETER
 100" DEEP (Actual depth - takes into account the 4" of backfill, ground cover and 8" of riser sticking out of the ground)

BOTTOM OF INLET PIPE TO BOTTOM OF TANK IS 67"

NOTE:
 INSTALL MINIMUM 4" SAND OR PEA GRAVEL UNDER TANK



CARR CONCRETE
 CARR CONCRETE CORPORATION
 P.O. BOX -265, WAVERLY, WV 26184-0265

PHONE: 800-837-8918
 FAX: 304-464-4013

FILE#	DRAWN BY	ARM	DATE	3/18/92
2200 GALLON CISTERN				
ISOMETRIC VIEW				
DWG. NO.	1	6	5	6
REV	1	5/16/97	2	1/18/02
	3	3/3/05	4	4